



23 July 2019

Flammability of 3M Products

Classification of fire behavior

1.1 Product

Material: **3M™ Print Wrap Film IJ180mC-120 laminated with
3M™ Print Wrap Film IJ180mC-10UR**
Substrate: **Aluminium**

1.2 Commissioned Testing Institute

MPA NRW, Auf den Thränen 2, D-59597 Erwitte

1.3 Classified according to Standard: **DIN EN 13501-1:2010-01**

Fire classification of construction and building elements

Report of the classification of the reaction to fire performance no. 2310011619-3, 16 November 2018.

Classification using data from reaction to fire tests.

Testing according to DIN EN ISO 11925-2: Classification report no.: 2310011619-1, 16 November 2018

Testing according to DIN EN 13823: Classification report no.: 2310011619-2, 16 November 2018

1.4 With reference to the standard and the present test reports, the company 3M Deutschland GmbH confirms the following resulting overall classification.

C-s1, d0

The product 3M™ Print Wrap Film IJ180mC-120 laminated with 3M™ Print Wrap Film IJ180mC-10UR thus fulfills the requirement set according to the test report result C-s1, d0.

3M Deutschland GmbH

Commercial Solutions Division

Zillikens

This confirmation refers exclusively to the named product combination. The basis are the mentioned test reports of the commissioned test institutes for the classification of the fire behavior. The validity ends when the product or the referring standard is changed.