

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Plastics**

Type of material: self-adhesive plastic film made of vinyl  
Article description: Concept 103  
Dimensions: according to specification: 1372/1524 [mm] x 50 [m];  
test sample: 1000 x 500 x 0.125 [mm]  
Colour: clear, glossy  
Surface: even, fine-rough structured  
Producer/supplier: GENERAL FORMULATIONS  
309 S. UNION, SPARTA  
49345 Michigan / USA

Client: GF General Formulations GmbH  
Hansestraße 105  
51149 Köln

Certificate No.: 90982001.001  
(tested under: 85271802.002)

Test date: 06.12.2018

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method  
- Ramp test"  
The sample covering was delivered in a surface condition ready  
for testing.

Test result: Average total acceptance angle: **9,6°**


Assessment: **Classification group of anti-slip property: R 9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**

Institut für Wand- und Bodenbeläge

Managing Director

  
Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 22.06.2020  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIRT nach LRO unter der Kenn-Nr. NDS 20 anerkannte und nach EIL-BaupVO notifizierte Stelle NR 1212

